



# Certificate of Compliance

This certificate is issued for the following:

**Polyvinyl Chloride (PVC) Pipe and Fittings for Underground Fire Protection Service**

**RieberLok Gasket, Sizes 4-12 inch NPS**  
(See Listing Attached)

**Prepared for:**

Ransom International LLC  
1143 Vanderbilt Road  
Birmingham, AL 35234  
United States

**Manufactured at:**

Thong Nhat Rubber Company  
06 Nguyen Trong Quyen Street  
Tan Thoi Hoa Ward, Tan Phu District  
Ho Chi Minh City, Vietnam

FM Approvals Class: 1612

Approval Identification: PR450229

Approval Granted: July 11, 2018

To verify the availability of the Approved product, please refer to [www.approvalguide.com](http://www.approvalguide.com)

Said Approval is subject to satisfactory field performance, continuing Surveillance Audits, and strict conformity to the constructions as shown in the Approval Guide, an online resource of FM Approvals.

A handwritten signature in black ink, appearing to read 'D. B. Fuller', is written over a horizontal line.

David Fuller  
VP - Manager of Fire Protection  
FM Approvals  
1151 Boston-Providence Turnpike  
Norwood, MA 02062 USA



*Member of the FM Global Group*



# Certificate of Compliance

Bell Joint Restraint for AWWA C-900 DR18 PVC pipe. Used to restrain bell and spigot joints of PVC pipe.

<i>Description</i>	<i>Nominal Pipe Size, in.</i>	<i>Rated Working Pressure psi (kPa)</i>	<i>Remarks</i>
ReiberLok Restraining Gasket	4, 6, 8 and 12	150 (1035)	a, b

**Remarks:**

- a. For use with AWWA C900 DR18 Class 150 pipe.
- b. For use with AWWA C900 DR14 Class 200 pipe



*Member of the FM Global Group*