



Certificate of Compliance

This certificate is issued for the following:

Polyvinyl Chloride (PVC) Pipe and Fittings for Underground Fire Protection Service

RieberLok Gasket, Sizes 4-12 inch NPS
(See Listing Attached)

Prepared for:

Ransom International LLC
1143 Vanderbilt Road
Birmingham, AL 35234
United States

Manufactured at:

Thong Nhat Rubber Company
06 Nguyen Trong Quyen Street
Tan Thoi Hoa Ward, Tan Phu District
Ho Chi Minh City, Vietnam

FM Approvals Class: 1612

Approval Identification: PR450229

Approval Granted: July 11, 2018

To verify the availability of the Approved product, please refer to www.approvalguide.com

Said Approval is subject to satisfactory field performance, continuing Surveillance Audits, and strict conformity to the constructions as shown in the Approval Guide, an online resource of FM Approvals.

A handwritten signature in black ink that reads 'D.B. Fuller'.

David Fuller
VP - Manager of Fire Protection
FM Approvals
1151 Boston-Providence Turnpike
Norwood, MA 02062 USA



Member of the FM Global Group



Certificate of Compliance

Bell Joint Restraint for AWWA C-900 DR18 PVC pipe. Used to restrain bell and spigot joints of PVC pipe.

<i>Description</i>	<i>Nominal Pipe Size, in.</i>	<i>Rated Working Pressure psi (kPa)</i>	<i>Remarks</i>
ReiberLok Restraining Gasket	4, 6, 8 and 12	150 (1035)	a, b

Remarks:

- a. For use with AWWA C900 DR18 Class 150 pipe.
- b. For use with AWWA C900 DR14 Class 200 pipe



Member of the FM Global Group